

MOHONASEN CSD
BRADT E/S

Bradt Elementary School; 2719 Hamburg Street		Results	Action level	Unit
B-1	ROOM A1; SINK	3.5	15	ug/L
B-2	ROOM A1; BUBBLER	0.2	15	ug/L
B-3	ROOM A2; SINK	3.3	15	ug/L
B-4	ROOM A2; BUBBLER	<0.10	15	ug/L
B-5	ROOM A3; SINK	1.1	15	ug/L
B-6	ROOM A3; BUBBLER	<0.10	15	ug/L
B-7	ROOM A4; SINK	0.78	15	ug/L
B-8	ROOM A4; BUBBLER	45.7	15	ug/L
B-9	ROOM A5; SINK	1.6	15	ug/L
B-10	ROOM A5; BUBBLER	0.11	15	ug/L
B-11	ROOM A6; SINK	0.15	15	ug/L
B-12	ROOM A6; BUBBLER	0.13	15	ug/L
B-13	A-WING DRINKING FOUNTAIN	0.3	15	ug/L
B-14	A-WING BOYS BATHROOM RIGHT SINK	0.98	15	ug/L
B-15	A WING BOYS BATHROOM LEFT SINK	1.6	15	ug/L
B-16	A WING GIRLS BATHROOM RIGHT SINK	1.3	15	ug/L
B-17	A WING GIRLS BATHROOM LEFT SINK	1.5	15	ug/L
B-18	A WING SLOP SINK	0.27	15	ug/L
B-19	A WING OUTSIDE SPIGOT (FROM BATH)	20.3	15	ug/L
B-20	ROOM B3; SINK	5.4	15	ug/L
B-21	ROOM B3; BUBBLER	<0.10	15	ug/L
B-22	ROOM B4; SINK	4.4	15	ug/L
B-23	ROOM B4; BUBBLER	0.16	15	ug/L
B-24	ROOM B5; SINK	2.5	15	ug/L
B-25	ROOM B5; BUBBLER	<0.10	15	ug/L
B-26	ROOM B6; SINK	0.75	15	ug/L
B-27	ROOM B6; BUBBLER	0.12	15	ug/L
B-28	B WING DRINKING FOUNTAIN	0.28	15	ug/L
B-29	B WING BOYS ROOM RIGHT SINK	1.3	15	ug/L
B-30	B WING BOYS ROOM LEFT SINK			
B-31	B WING GIRLS ROOM RIGHT SINK	0.5	15	ug/L
B-32	B WING GIRLS ROOM LEFT SINK	<0.10	15	ug/L
B-33	B WING SLOP SINK	0.14	15	ug/L
B-34	B WING OUTSIDE SPIGOT (FROM BATH)	72.1	15	ug/L
B-35	LIBRARY SINK (TOP OF B WING)	0.7	15	ug/L
B-36	ART ROOM WORK SINK	0.39	15	ug/L
B-37	ART ROOM BATHROOM SINK	0.87	15	ug/L
B-38	NURSES OFFICE SINK (OFF MAIN HALL)	0.71	15	ug/L
B-39	BOILER ROOM DEEP SINK	0.87	15	ug/L
B-40	MAIN HW BATHROOM SINK	0.2	15	ug/L
B-41	MAIN HW DF (ACROSS FROM CAFÉ)	<0.10	15	ug/L
B-42	MENS BATHROOM BACK OF CAFÉ SINK	0.5	15	ug/L
B-43	WMNS BATHROOM BACK OF CAFÉ SINK	0.63	15	ug/L
B-44	KIT D/W SPRAYER	2.0	15	ug/L

MOHONASEN CSD

BRADT E/S

B-45	KIT 3 BAY SINK RIGHT FAUCET	0.27	15	ug/L
B-46	KIT 3 BAY SINK LEFT FAUCET	<0.10	15	ug/L
Bradt Elementary School; 2719 Hamburg Street		Results	Action level	Unit
B-47	KIT 2 BAY SINK FAUCET			
B-48	KIT HAND WASHING SINK	0.72	15	ug/L
B-49	MUSIC ROOM BATHROOM	0.77	15	ug/L
B-50	MUSIC ROOM DRINKING FOUNTAIN	3.5	15	ug/L
B-51	ROOM C1 SINK (FACULTY ROOM)	0.39	15	ug/L
B-52	ROOM C1 BATHROOM SINK (FAC ROOM)	0.59	15	ug/L
B-53	ROOM C2 SINK	4.2	15	ug/L
B-54	ROOM C2 BUBBLER	0.12	15	ug/L
B-55	ROOM C2 BATHROOM SINK	0.85	15	ug/L
B-56	ROOM C3 SINK	2.7	15	ug/L
B-57	ROOM C3 BUBBLER	4.6	15	ug/L
B-58	ROOM C4 SINK	2.9	15	ug/L
B-59	ROOM C4 BUBBLER	0.18	15	ug/L
B-60	ROOM C5 SINK	2.7	15	ug/L
B-61	ROOM C5 BUBBLER	0.51	15	ug/L
B-62	ROOM C6 SINK	3.6	15	ug/L
B-63	ROOM C 6 BUBBLER	0.37	15	ug/L
B-64	C WING DRINKING FOUNTAIN	0.78	15	ug/L
B-65	C WING BOYS ROOM RIGHT SINK	0.95	15	ug/L
B-66	C WING BOYS ROOM LEFT SINK	2.1	15	ug/L
B-67	C WING GIRLS ROOM RIGHT SINK	0.61	15	ug/L
B-68	C WING GIRLS ROOM LEFT SINK	1.3	15	ug/L
B-69	C WING SLOP SINK	0.59	15	ug/L
B-70	C WING OUTSIDE SPIGOT (FROM BATH)	8.5	15	ug/L
B-71	BRES 154 RMD2A Sink	5.7	15	ug/L
B-72	BRES 155 RMD2A Bubbler	3.5	15	ug/L
B-73	ROOM D3B SINK			
B-74	ROOM D3B BUBBLER			
B-75	ROOM D3A SINK	32	15	ug/L
B-76	ROOM D3A BUBBLER			
B-77	ROOM D4 SINK	2.2	15	ug/L
B-78	ROOM D4 BUBBLER	0.12	15	ug/L
B-79	ROOM D5 SINK	2.3	15	ug/L
B-80	ROOM D5 BUBBLER	0.11	15	ug/L
B-81	ROOM D6 SINK	4.2	15	ug/L
B-82	ROOM D6 BUBBLER	<0.10	15	ug/L
B-82	BRES 082B D7 Sink	0.16	15	ug/L
B-83	ROOM D7 BUBBLER	0.16	15	ug/L
B-84	D WING DRINKING FOUNTAIN	0.14	15	ug/L
B-85	D WING BOYS ROOM RIGHT SINK	0.85	15	ug/L
B-86	D WING BOYS ROOM LEFT SINK	1.3	15	ug/L
B-87	D WING GIRLS ROOM RIGHT SINK	1.1	15	ug/L

MOHONASEN CSD
BRADT E/S

B-88	D WING GIRLS ROOM LEFT SINK	1.1	15	ug/L
B-89	D WING SLOP SINK	0.2	15	ug/L
B-90	D WING OUTSIDE SPIGOT (FROM BATH)	1.5	15	ug/L
B-91	ROOM F1 SINK	3.3	15	ug/L
Bradt Elementary School; 2719 Hamburg Street		Results	Action level	Unit
B-92	ROOM F1 BUBBLER	0.4	15	ug/L
B-93	ROOM F1 BATHROOM SINK	0.55	15	ug/L
B-94	ROOM F2 SINK	0.14	15	ug/L
B-95	ROOM F2 BUBBLER	0.47	15	ug/L
B-96	ROOM F2 BATHROOM SINK	0.41	15	ug/L
B-97	ROOM F3 SINK	0.4	15	ug/L
B-98	ROOM F3 BUBBLER	0.12	15	ug/L
B-99	ROOM F3 BATHROOM SINK	19.0	15	ug/L
B-100	ROOM F4 SINK	2.2	15	ug/L
B-101	ROOM F4 BUBBLER	0.14	15	ug/L
B-102	ROOM F4 BATHROOM SINK	4.3	15	ug/L
B-103	ROOM F5 SINK	0.96	15	ug/L
B-104	ROOM F5 BUBBLER	0.17	15	ug/L
B-105	ROOM F5 BATHROOM SINK	0.54	15	ug/L
B-106	ROOM F6 SINK	0.13	15	ug/L
B-107	ROOM F6 BUBBLER	1.5	15	ug/L
B-108	ROOM F6 BATHROOM SINK	4.2	15	ug/L
B-109	ROOM F7 SINK	1.1	15	ug/L
B-110	ROOM F7 BUBBLER	0.18	15	ug/L
B-111	ROOM F7 BATHROOM SINK	13.9	15	ug/L
B-112	ROOM F8 SINK	0.14	15	ug/L
B-113	ROOM F8 BUBBLER	1.9	15	ug/L
B-114	ROOM F8 BATHROOM SINK	12.2	15	ug/L
B-115	ROOM F9 SINK	0.13	15	ug/L
B-116	ROOM F9 BUBBLER	0.13	15	ug/L
B-117	ROOM F9 BATHROOM SINK	0.75	15	ug/L
B-118	ROOM F10 SINK	0.59	15	ug/L
B-119	ROOM F10 BUBBLER	0.14	15	ug/L
B-120	ROOM F10 BATHROOM SINK	23.5	15	ug/L
B-121	WATER FOUNTAIN ACROSS FROM GYM	3.6	15	ug/L
B-122	OT/PT SINK (ACROSS FROM GYM)	10.6	15	ug/L
B-123	SPEECH RM SINK (ACROSS FROM GYM)	5.8	15	ug/L
B-124	ROOM E1 SINK	0.12	15	ug/L
B-125	ROOM E1 BUBBLER	0.24	15	ug/L
B-126	ROOM E2 SINK	62.1	15	ug/L
B-127	ROOM E2 BUBBLER	0.15	15	ug/L
B-128	ROOM E3 SINK	1.7	15	ug/L
B-129	ROOM E3 BUBBLER	0.3	15	ug/L
B-130	ROOM E4 SINK	13.6	15	ug/L
B-131	ROOM E4 BUBBLER	0.1	15	ug/L

