

MOHONASEN CSD
DRAPER MIDDLE SCHOOL

Draper Middle School; 2070 Curry Road		RESULTS	ACTION LEVEL	UNITS
D-1	RM 111 RIGHT SINK	0.68	15	ug/L
D-2	RM 111 LEFT SINK	10.6	15	ug/L
D-3	RM 112 RIGHT SINK	1.3	15	ug/L
D-4	RM 112 LEFT SINK	11.7	15	ug/L
D-5	RM 113 RT SINK RT FAUCET	12.2	15	ug/L
D-6	RM 113 RT SINK CTR FAUCET	1.5	15	ug/L
D-7	RM 113 RT SINK LFT FAUCET	12.3	15	ug/L
D-8	RM 113 CTR SINK RT FAUCET	16.0	15	ug/L
D-9	RM 113 CTR SINK CTR FAUCET	1.2	15	ug/L
D-10	RM 113 CTR SINK LFT FAUCET	17.0	15	ug/L
D-11	RM 113 LFT SINK RT FAUCET	6.3	15	ug/L
D-12	RM 113 LFT SINK CTR FAUCET	5.6	15	ug/L
D-12	SEE SAMPLE D-129			
D-13	RM 114 SINK 1	0.77	15	ug/L
D-14	RM 114 SINK 2	0.65	15	ug/L
D-15	RM 114 SINK 3	1.2	15	ug/L
D-16	RM 114 SINK 4	2.1	15	ug/L
D-17	BOYS RM BY RM 114 RT SINK	1.0	15	ug/L
D-18	BOYS RM BY RM 114 CTR SINK	0.93	15	ug/L
D-19	BOYS RM BY RM 114 LFT SINK	1.6	15	ug/L
D-20	GIRLS RM BY RM 114 RT SINK	1.0	15	ug/L
D-21	GIRLS RM BY RM 114 CTR SINK	9.0	15	ug/L
D-22	GIRLS RM BY RM 114 LFT SINK	1.5	15	ug/L
D-23	SLOP SINK BY RM 114	1.4	15	ug/L
D-24	NURSES OFFICE SINK EXAM RM	1.7	15	ug/L
D-25	NURSES OFFICE BATH	0.88	15	ug/L
D-26	NURSES OFFICE MAIN	0.82	15	ug/L
D-27	FAC BR BY NURSES OFFICE	0.83	15	ug/L
D-28	GIRLS BATH BY NURSES OFC RT	1.3	15	ug/L
D-29	GIRLS BATH BY NURSES OFC LFT	1.1	15	ug/L
D-30	BOYS BATH BY NURSES OFC RT	90.4	15	ug/L
D-31	BOYS BATH BY NURSES OFC LFT	1.2	15	ug/L
D-32	KITCHEN IN MN OFC	0.57	15	ug/L
D-33	MENS RM MN OFC	7.2	15	ug/L
D-34	LADIES RM MN OFC	6.9	15	ug/L
D-35	MENS RM BY KITCHEN RT FAUCET	2.4	15	ug/L
D-36	MENS RM BY KITCHEN CTR FAUCET	1.9	15	ug/L
D-37	MENS RM BY KITCHEN LFT FAUCET	1.3	15	ug/L
D-38	WMNS RM BY KITCHEN RT FAUCET	1.7	15	ug/L
D-39	WMNS RM BY KITCHEN CTR FAUCET	0.84	15	ug/L
D-40	WMNS RM BY KITCHEN LFT FAUCET	1.2	15	ug/L
D-41	RM 101 SINK	5.0	15	ug/L
D-42	RM 102 SINK	1.8	15	ug/L
D-43	GRLS RM ACROSS FRM LOCKER RM RT SINK	1.1	15	ug/L

MOHONASEN CSD
DRAPER MIDDLE SCHOOL

D-44	GRLS RM ACROSS FRM LOCKER RM LFT SINK	1.4	15	ug/L
D-45	BOYS RM ACROSS FRM LOCKER RM RT SINK	89.5	15	ug/L
Draper Middle School; 2070 Curry Road		RESULTS	ACTION LEVEL	UNITS
D-46	BOYS RM ACROSS FRM LOCKER RM LFT SINK	0.96	15	ug/L
D-47	SLOP SINK LOCKER ROOM	1.0	15	ug/L
D-48	WATER FOUNTAIN BY LOCKER ROOM	<0.10	15	ug/L
D-49	BOYS COACHES OFFICE SINK	6.9	15	ug/L
D-50	BOYS LOCKER ROOM RT SINK	1.5	15	ug/L
D-51	BOYS LOCKER ROOM LFT SINK	1.5	15	ug/L
D-52	GIRLS COACHES OFFICE SINK	11.0	15	ug/L
D-53	GIRLS LOCKER ROOM RT SINK	1.5	15	ug/L
D-54	GIRLS LOCKER RM LFT SINK	1.8	15	ug/L
D-55	WATER FOUNTAIN GIRLS LOCKER ROOM	0.43	15	ug/L
D-56	SLOP SNK BY ROOM 104	17.8	15	ug/L
D-57	WATER FOUNTAIN BY RM 93	0.19	15	ug/L
D-58	BTHROOM SINK BY RM 93	0.86	15	ug/L
D-59	SLOP SINK BY KITCHEN	0.76	15	ug/L
D-60	KITCHEN SINK RT FAUCET	2.1	15	ug/L
D-61	KITCHEN SINK LFT FAUCET	1.3	15	ug/L
D-62	SINK IN BACK OF LIBRARY	8.9	15	ug/L
D-63	FACULTY RM SINK	3.1	15	ug/L
D-64	WMNS RM FACULTY	1.2	15	ug/L
D-65	MENS RM FACULTY	1.2	15	ug/L
D-66	SLOP SINK BY RM 219	2.8	15	ug/L
D-67	RM 200 SINK	0.66	15	ug/L
D-68	WATER FOUNTAIN BY RM 200	0.55	15	ug/L
D-69	BOYS RM BY 219 RT SINK	1.0	15	ug/L
D-70	BOYS RM BY 219 LFT SINK	0.75	15	ug/L
D-71	GRLS RM BY 219 RT SINK	1.7	15	ug/L
D-72	GRLS RM BY 219 LFT SINK	1.7	15	ug/L
D-73	PREP RM 219 SINK (Does not work)	N/A	N/A	N/A
D-74	RM 219 SINK 1	8.7	15	ug/L
D-75	RM 219 SINK 2	18.9	15	ug/L
D-76	RM 219 SINK 3	14.9	15	ug/L
D-77	RM 219 SINK 4	112	15	ug/L
D-78	RM 219 SINK 5	8,110	15	ug/L
D-79	PREP RM 218 SINK (Doesn't work)			
D-80	RM 218 RT SINK (No Faucet)			
D-81	RM 218 CTR SINK	18.1	15	ug/L
D-82	RM 218 LFT SINK (No Faucet)			
D-83	RM 217 SINK 1 (Left)	33.1	15	ug/L
D-84	RM 217 SINK 2	12.9	15	ug/L
D-85	RM 217 SINK 3	6.7	15	ug/L
D-86	RM 217 SINK 4	19.1	15	ug/L
D-87	RM 217 SINK 5 (Teacher Desk)	93.1	15	ug/L

MOHONASEN CSD
DRAPER MIDDLE SCHOOL

D-88	RM 216 SINK 1 (Right)	3.7	15	ug/L
D-89	RM 216 SINK 2	10.3	15	ug/L
D-90	RM 216 SINK 3	9.6	15	ug/L
D-91	RM 216 SINK 4	86.2	15	ug/L
Draper Middle School; 2070 Curry Road		RESULTS	ACTION LEVEL	UNITS
D-92	RM 216 SINK 4 Teachers Desk)	41.4	15	ug/L
D-93	PREP RM SINK 215 (Doesn't Work)	N/A	N/A	N/A
D-94	RM 215 SINK 1 (Teachers Desk)	36.9		ug/L
D-95	RM 215 SINK 2	11.8	15	ug/L
D-96	RM 215 SINK 3	21.9	15	ug/L
D-97	RM 215 SINK 4	56.5	15	ug/L
D-98	RM 215 SINK 5 (Left)	26.3	15	ug/L
D-99	PREP RM SINK 214	19.4	15	ug/L
D-100	RM 214 RT SINK	31.8	15	ug/L
D-101	RM 214 CTR SINK (No, faucet)			
D-102	RM 214 LFT SINK (No Faucet)			
D-103	BOYS RM BY RM 212 RT SINK	1.2	15	ug/L
D-104	BOYS RM BY RM 212 CTR SINK	0.87	15	ug/L
D-105	BOYS RM BY RM 212 LFT SINK	1.5	15	ug/L
D-106	GRLS RM BY RM 212 RT SINK	1.3	15	ug/L
D-107	GRLS RM BY RM 212 CTR SINK	1.4	15	ug/L
D-108	GRLS RM BY RM 212 LFT SINK	1.9	15	ug/L
D-109	SLOP SINK BY RM 212	2.5	15	ug/L
D-110	WATER FOUNTAIN BY RM 212	0.63	15	ug/L
D-111	WATER FOUNTAIN BY RM 203 (Broken)	N/A	N/A	N/A
D-112	OUTSIDE SPIGOT BY RM 101	11.2	15	ug/L
D-113	OUTSIDE SPIGOT BY CAFÉ (Broken)			
D-114	OUTSIDE SPIGOT BY MPR	25.9	15	ug/L
D-115	OUTSIDE SPIGOT BY RM 110	6.5	15	ug/L
D-116	OUTSIDE SPIGOT BY RM 113	20.7	15	ug/L
D-117	OUTSIDE SPIGOT BY RM 121	20.8	15	ug/L
D-118	OUTSIDE SPIGOT BY GUIDANCE	1.5	15	ug/L
D-119	WATER FOUNTAIN OUTSIDE NURSES	0.5	15	ug/L
D-120	CONCESSION STAND FACUET (No Faucet)			
D-121	CONCESSION STAND SPRAYER	0.67	15	ug/L
D-122	FOOTBALL FIELD GRLS RM SINK RT	1.3	15	ug/L
D-123	FOOTBALL FIELD GRLS RM SINK CTR (Broken)	N/A	N/A	N/A
D-124	FOOTBALL FIELD GRLS RM SINK LFT	1.8	15	ug/L
D-125	FOOTBALL FIELD BOYS RM SNK RT	2.2	15	ug/L
D-126	FOOBALL FIELD BOYS RM SNK CTR (Broken)	N/A	N/A	N/A
D-127	FOOTBALL FIELD BOYS RM SNK LEFT	1.3	15	ug/L
D-128	OLD CONCESSION STAND DEEP SINK	6.2	15	ug/L
D-129	RM 113 LEFT SINK	5.9	15	ug/L
D-130	RM 114 SINK 5, TEACHERS	5.6	15	ug/L
D-131	WATERFOUNTAIN OUTSIDE RM 115	0.64	15	ug/L

