

MOHONASEN CSD
HIGH SCHOOL

HIGH SCHOOL 2072 Curry Road		RESULT	ACTION LEVEL	UNIT
HS-1	KIT SLOP SINK	3.2	15	ug/L
HS-2	KIT HAND WASH SINK	1.5	15	ug/L
HS-3	KIT D/W SPRAYER	1.4	15	ug/L
HS-4	KIT D/W SINK RT	14.6	15	ug/L
HS-5	KIT D/W SINK LFT	20.2	15	ug/L
HS-6	KIT SCULLERY SINK RT FAUCET	2.5	15	ug/L
HS-7	KIT SCULLERY SINK LFT FAUCET	1.7	15	ug/L
HS-8	KIT POT FILLER 1	8.4	15	ug/L
HS-9	KIT POT FILLER 2	0.75	15	ug/L
HS-10	AUD LOBBY SLOP SINK	0.8	15	ug/L
HS-11	AUD LOBBY W/F	0.32	15	ug/L
HS-12	AUD LOBBY GRLS RM RT SINK	1.7	15	ug/L
HS-13	AUD LOBBY GRLS RM LFT SINK	1.1	15	ug/L
HS-14	AUD LOBBY BOYS RM RT SINK	0.66	15	ug/L
HS-15	AUD LOBBY BOYS RM LFT SINK	1.2	15	ug/L
HS-16	SPIGOT OUTSIDE AUD MAIN ENTRANCE	8.1	15	ug/L
HS-17	SPIGOT OUTSIDE AUD GARAGE (None)	N/A	N/A	N/A
HS-18	MUSIC WING GRLS RM RT SINK	1.3	15	ug/L
HS-19	MUSIC WING GRLS RM LFT SINK	1.3	15	ug/L
HS-20	MUSIC WING BOYS RM	0.69	15	ug/L
HS-21	MUSIC WING OFFICE SINK	0.73	15	ug/L
HS-22	NURSES OFC B/R SINK	2.5	15	ug/L
HS-23	NURSES OFC EXAM RM	2.1	15	ug/L
HS-24	NURSES OFC H/W SINK	0.84	15	ug/L
HS-25	NURSES OFFICE WORK SINK	1.7	15	ug/L
HS-26	MAINT OFC WORK SINK	2.3	15	ug/L
HS-27	TECH WING GRLS RM SINK	0.95	15	ug/L
HS-28	TECH WING BOYS RM SINK	0.81	15	ug/L
HS-29	SLOP SINK ACROSS FRM RM 6	0.79	15	ug/L
HS-30	SPIGOT OUTSIDE RM 19	0.4	15	ug/L
HS-31	RM 19 SINK 1	1.4	15	ug/L
HS-32	RM 19 SINK 2	2.0	15	ug/L
HS-33	RM 19 SINK 3	1.8	15	ug/L
HS-34	RM 19 SINK 4	1.5	15	ug/L
HS-35	FAC RM B SINK	1.0	15	ug/L
HS-36	FAC RM B WMNS SINK	1.2	15	ug/L
HS-37	FAC RM B MNS SINK	2.1	15	ug/L
HS-38	SERVING LINE B SINK	1.6	15	ug/L
HS-39	CAFÉ B SNACK SHACK	0.7	15	ug/L
HS-40	CAFÉ B WTRFNTN	<0.10	15	ug/L
HS-41	LGI GRLS RM RT SINK	0.72	15	ug/L
HS-41A	LGI GRLS RM CTR	N/A	N/A	N/A
HS-42	LGI GRLS RM LFT SINK	1.0	15	ug/L
HS-43	LGI BOYS RM RT SINK	1.4	15	ug/L

MOHONASEN CSD
HIGH SCHOOL

HS-44	LGI BOYS LFT SINK	1.3	15	ug/L
HS-45	LGI SLOP SINK	0.28	15	ug/L
HIGH SCHOOL 2072 Curry Road		RESULT	ACTION LEVEL	UNIT
HS-46	RM 21 SINK	0.84	15	ug/L
HS-47	LIB SNK 1	0.88	15	ug/L
HS-48	LIB LOBBY GRLS RM SINK	0.69	15	ug/L
HS-49	LIB LOBBY BOYS RM SINK	1.0	15	ug/L
HS-50	LIB LOBBY SLOP SINK	2.6	15	ug/L
HS-51	RM 50 HW WALL RT SINK	51.4	15	ug/L
HS-52	RM 50 HW WALL CTR SINK	3.9	15	ug/L
HS-53	RM 50 HW WALL LFT SINK	4.9	15	ug/L
HS-54	RM 50 WINDOW WALL RT SINK	6.8	15	ug/L
HS-55	RM 50 WINDOW WALL CTR SINK	3.5	15	ug/L
HS-56	RM 50 WINDOW WALL LFT SINK	3.7	15	ug/L
HS-57	RM 50 BACK WALL RT SINK	2.1	15	ug/L
HS-58	RM 50 BACK WALL CTR SINK	3.7	15	ug/L
HS-59	RM 50 BACK WALL LFT SINK	5.6	15	ug/L
HS-60	RM 60 LFT WALL SNK RT FAUCET	4.9	15	ug/L
HS-61	RM 60 LFT WALL SNK CTR FAUCET	2.5	15	ug/L
HS-62	RM 60 LEFT WALL SNK LFT FAUCET	2.4	15	ug/L
HS-63	RM 60 RIGHT WALL SNK RT FAUCET	1.2	15	ug/L
HS-64	RM 60 RIGHT WALL SNK CTR FAUCET	N/A	N/A	N/A
HS-65	RM 60 RIGHT WALL SNK LFT FAUCET	4.0	15	ug/L
HS-66	RM 61 LFT WALL SNK RT FAUCET	0.25	15	ug/L
HS-67	RM 61 LFT WALL SNK CTR FAUCET	2.9	15	ug/L
HS-68	RM 61 LEFT WALL SNK LFT FAUCET	1.1	15	ug/L
HS-69	RM 61 RIGHT WALL SNK RT FAUCET	N/A	N/A	N/A
HS-70	RM 61 RIGHT WALL SNK CTR FAUCET	N/A	N/A	N/A
HS-71	RM 61 RIGHT WALL SNK LFT FAUCET	N/A	N/A	N/A
HS-72	RM 66 HW SNK RT FAUCET	2.2	15	ug/L
HS-73	RM 66 HW SNK CTR FAUCET	2.5	15	ug/L
HS-74	RM 66 HW SNK LFT FAUCET	1.7	15	ug/L
HS-75	ART LOBBY WTR FOUNTAIN HIGH	0.11	15	ug/L
HS-76	ART LOBBY WATER FOUNTAIN LOW	0.11	15	ug/L
HS-77	GRLS RM ACROSS FRM RM 46 RT SNK	0.42	15	ug/L
HS-78	GRLS RM ACROSS FRM RM 46 CTR SNK	N/A	N/A	N/A
HS-79	GRLS RM ACROSS FRM RM 46 LFT SNK	0.18	15	ug/L
HS-80	BOYS RM ACROSS FRM RM 46 RT SNK	0.57	15	ug/L
HS-81	BOYS RM ACROSS FRM RM 46 LFT SNK	0.68	15	ug/L
HS-82	SLOP SNK ACROSS FRM RM 46	0.2	15	ug/L
HS-83	CAFÉ A SNACK SHACK SNK	0.26	15	ug/L
HS-84	CAFÉ A SERVING LINE SNK	14.2	15	ug/L
HS-85	CAFÉ A WTR FOUNTAIN	0.88	15	ug/L
HS-86	D/O MENS RM	6.3	15	ug/L
HS-87	D/O WMNS RM	0.53	15	ug/L

MOHONASEN CSD
HIGH SCHOOL

HS-88	D/O BRK RM	0.45	15	ug/L
HS-89	RM 48 SINK	1.3	15	ug/L
HS-90	RM 35 TCHRS STA	19.0	15	ug/L
HS-91	RM 35 SNK 1	8.4	15	ug/L
HIGH SCHOOL 2072 Curry Road		RESULT	ACTION LEVEL	UNIT
HS-92	RM 35 SNK 2	4.6	15	ug/L
HS-93	RM 35 SNK 3	2.0	15	ug/L
HS-94	RM 35 SNK 4	1.6	15	ug/L
HS-95	RM 35 SNK 5	1.7	15	ug/L
HS-96	RM 35 SNK 6	2.1	15	ug/L
HS-97	RM 35 SNK 7	0.26	15	ug/L
HS-98	RM 35 SNK 8	1.8	15	ug/L
HS-99	RM 35 SNK 9	2.1	15	ug/L
HS-100	RM 35 SNK 10	5.9	15	ug/L
HS-101	RM 35 SNK 11	2.3	15	ug/L
HS-102	RM 35 SNK 12	5.0	15	ug/L
HS-103	RM 35 SNK 13	N/A	N/A	N/A
HS-104	RM 35 SNK 14	N/A	N/A	N/A
HS-105	POOL MECH RM HOSE REEL	1.8	15	ug/L
HS-106	POOL GRLS LKR RM SNK RT FAUCET	1.5	15	ug/L
HS-107	POOL GRLS LKR RM SNK CTR FAUCET	1.9	15	ug/L
HS-108	POOL GRLS LKR RM SNK LFT FAUCET	1.4	15	ug/L
HS-109	POOL OFFICE SINK	0.73	15	ug/L
HS-110	POOL BOYS LKR RM LFT SNK RT FAUCET	0.91	15	ug/L
HS-111	POOL BOYS LKR RM LFT SNK CTR FAUCET	N/A	N/A	N/A
HS-112	POOL BOYS LKR RM LFT SNK LFT FAUCET	0.99	15	ug/L
HS-113	POOL BOYS LKR RM RT SNK RT FAUCET	2.0	15	ug/L
HS-114	POOL BOYS LKR RM RT SNK CTR FAUCET	N/A	N/A	N/A
HS-115	POOL BOYS LKR RM RT SNK LFT FAUCET	N/A	N/A	N/A
HS-116	POOL LOBBY FOUNTAIN	0.22	15	ug/L
HS-117	TMP LKR RM WTR FTN	0.21	15	ug/L
HS-118	TMP LKR RM STALL 2 (Broken)	N/A	N/A	N/A
HS-119	TMP LKR RM STALL 3	2.2	15	ug/L
HS-120	TMP LKR RM STALL 4 (Broken)	N/A	N/A	N/A
HS-121	TMP LKR RM COACHES OFFICE	1.6	15	ug/L
HS-122	SPIGOT OUTSIDE PE ENTRANCE (Broken)	N/A	N/A	N/A
HS-123	WTR FOUNTAIN PE ENTRANCE	0.44	15	ug/L
HS-124	GYM LOBBY FOUNTAIN	0.26	15	ug/L
HS-125	GYM LOBBY GRLS RM RT SINK	1.2	15	ug/L
HS-125	GYM LOBBY GRLS RM CTR SNK	0.49	15	ug/L
HS-126	GYM LOBBY GRLS RM LFT SNK	0.6	15	ug/L
HS-127	GYM LOBBY BOYS RM RT SNK	0.88	15	ug/L
HS-128	GYM LOBBY BOYS RM CTR SNK	0.75	15	ug/L
HS-129	GYM LOBBY BOYS RM LFT SNK	1.1	15	ug/L
HS-130	GREEN HOUSE HOSE BIB	0.75	15	ug/L

