

MOHONASEN CSD
PINEWOOD E/S

Pinewood Elementary School; 901 Kings Road		Results	Action Level	Unit
P-1	KITCHEN DISHWASHER SPRAYER	0.53	15	ug/L
P-2	KIT. 3 BAY SINK RT FAUCET (SPYR)	O=44.7/R=.45	15	ug/L
P-3	HAND SINK BY DISHWASHER	O=40.4/R=2.9	15	ug/L
P-4	KIT. 3 BAY SINK LFT FAUCET	5.3	15	ug/L
P-5	KIT. STOVE POT FILLER	O=87.9/R=3.4	15	ug/L
P-6	KIT. SINK ACROSS FROM STOVE RIGHT	O=22.4/R=5.4	15	ug/L
P-7	KIT. SINK ACROSS FROM STOVE LEFT	O=12.2/R=2.7	15	ug/L
P-8	SERV LINE WELL FILL RT	6.3	15	ug/L
P-9	SERV LINE WELL FILL CTR	N/A	N/A	N/A
P-10	SERV LINE WELL FILL LFT	2.0	15	ug/L
P-11	CAFÉ. WATER FOUNTAIN	0.11	15	ug/L
P-12	CAFÉ. BATH SINK	0.52	15	ug/L
P-13	WMNS ROOM SINK RT TOP OF 3RD GR WING	0.76	15	ug/L
P-14	WMNS ROOM SINK LFT TOP OF 3RD GR WING	1.3	15	ug/L
P-15	SLOP SINK TOP OF 3RD GRD WING	0.2	15	ug/L
P-16	W/F TOP OF 3RD GRADE WING	<0.10	15	ug/L
P-16A	W/F TOP OF 3RD GRADE WING (POR)	<0.10	15	ug/L
P-17	ROOM 1 SINK	O=19.1/1.9	15	ug/L
P-17A	RM 1 PORCELAIN	O=0.76/R=1.4	15	ug/L
P-17B	MENS RM SINK TOP OF 3RD GRD WING	1.2	15	ug/L
P-18	ROOM 1 FOUNTAIN	0.31	15	ug/L
P-19	ROOM 2 SINK	0.95	15	ug/L
P-20	ROOM 2 FOUNTAIN	0.84	15	ug/L
P-20A	ROOM 2 POR SINK	2.7	15	ug/L
P-21	ROOM 3 SINK	0.69	15	ug/L
P-22	ROOM 3 FOUNTAIN	3.0	15	ug/L
P-22A	ROOM 3 POR SINK	1.4	15	ug/L
P-23	ROOM 4 SINK	0.56	15	ug/L
P-24	ROOM 4 FOUNTAIN	0.22	15	ug/L
P-24A	ROOM 4 POR SINK	2.3	15	ug/L
P-25	ROOM 5 SINK	12.4	15	ug/L
P-26	ROOM 5 FOUNTAIN	10.1	15	ug/L
P-26A	ROOM 5 POR SINK	1.1	15	ug/L
P-27	ROOM 6 SINK	0.49	15	ug/L
P-28	ROOM 6 FOUNTAIN	2.2	15	ug/L
P-28A	ROOM 6 POR SINK	2.2	15	ug/L
P-29	ROOM 7 SINK	2.1	15	ug/L
P-30	ROOM 7 FOUNTAIN	0.52	15	ug/L
P-30A	ROOM 7 POR SINK	0.81	15	ug/L
P-31	ROOM 8 SINK	1.5	15	ug/L
P-32	ROOM 8 FOUNTAIN	0.24	15	ug/L
P-32A	ROOM 8 POR SINK	3.2	15	ug/L
P-33	ROOM 9 SINK	5.9	15	ug/L
P-34	ROOM 9 FOUNTAIN	2.5	15	ug/L
P-34A	RM 9/11 BOYS RM	0.9	15	ug/L

MOHONASEN CSD
PINEWOOD E/S

P-34B	RM 9/11 GRLS RM	1.8	15	ug/L
Pinewood Elementary School; 901 Kings Road		Results	Action Level	Unit
P-35	ROOM 10 SINK	4.2	15	ug/L
P-36	ROOM 10 FOUNTAIN	1.3	15	ug/L
P-36A	ROOM 10/12 GRLS ROOM	1.7	15	ug/L
P-36B	ROOM 10/12 BOYS ROOM	0.52	15	ug/L
P-37	ROOM 11 SINK	3.6	15	ug/L
P-38	ROOM 11 FOUNTAIN	0.81	15	ug/L
P-39	ROOM 12 SINK	2.3	15	ug/L
P-40	ROOM 12 FOUNTAIN	0.61	15	ug/L
P-41	WATER FOUNTAIN OUTSIDE ROOM 10	0.75	15	ug/L
P-41A	RM 10/12 GRLS RM	0.57	15	ug/L
P-42	NURSES OFFICE SINK	0.36	15	ug/L
P-42A	RM 12 BOYS RM	1.5	15	ug/L
P-43	LIBRARY SINK	11.4	15	ug/L
P-44	BOILER ROOM SINK	1.3	15	ug/L
P-45	RM 15 SINK	2.9	15	ug/L
P-46	RM 15 FOUNTAIN	0.32	15	ug/L
P-47	RM 17 SINK	4.6	15	ug/L
P-48	RM 17 FOUNTAIN	0.51	15	ug/L
P-49	ROOM 19 SINK	2.1	15	ug/L
P-50	RM 19 FOUNTAIN	0.58	15	ug/L
P-51	RM 19/21 GIRLS RM	0.32	15	ug/L
P-52	RM 19/21 BOYS RM	1.0	15	ug/L
P-53	RM 21 SINK	0.45	15	ug/L
P-54	RM 21 FOUNTAIN	0.36	15	ug/L
P-55	RM 23 SINK	1.7	15	ug/L
P-56	RM 23 FOUNTAIN	0.8	15	ug/L
P-57	RM 23/25 GIRLS RM	0.69	15	ug/L
P-58	RM 23/25 BOYS RM	1.9	15	ug/L
P-59	RM 27 SINK	1.8	15	ug/L
P-60	RM 27 FOUNTAIN	<0.10	15	ug/L
P-61	RM 27/29 GIRLS RM	0.62	15	ug/L
P-62	RM 27/29 BOYS RM	0.62	15	ug/L
P-63	RM 29 SINK	0.38	15	ug/L
P-64	RM 29 FOUNTAIN	<0.10	15	ug/L
P-65	RM 30 SINK	1.4	15	ug/L
P-66	RM 30 FOUNTAIN	<0.10	15	ug/L
P-67	RM 30/28 GIRLS RM	0.41	15	ug/L
P-68	RM 30/28 BOYS RM	0.71	15	ug/L
P-69	RM 28 SINK	0.63	15	ug/L
P-70	RM 28 FOUNTAIN	<0.10	15	ug/L
P-71	RM 26 SINK	0.55	15	ug/L
P-72	RM 26 FOUNTAIN	0.16	15	ug/L
P-73	RM 26/24 GIRLS RM	0.2	15	ug/L
P-74	RM 26/24 BOYS RM	0.99	15	ug/L
P-75	RM 22 SINK	1.1	15	ug/L

MOHONASEN CSD
PINEWOOD E/S

P-76	RM 22 FOUNTAIN	O=26.5/R=32.8	15	ug/L
Pinewood Elementary School; 901 Kings Road		Results	Action Level	Unit
P-77	RM 22/20 GIRLS RM	O=42.1/R=2.1	15	ug/L
P-78	RM 22/20 BOYS RM	1.1	15	ug/L
P-79	RM 20 SINK	0.69	15	ug/L
P-80	RM 20 FOUNTAIN	0.33	15	ug/L
P-81	RM 18 S/S SINK	O=56/R=3.6	15	ug/L
P-82	RM 18 FOUNTAIN	0.58	15	ug/L
P-82A	RM 18 POR SINK	O=1.4/R=1.1	15	ug/L
P-83	RM 18/16 GIRLS RM	1.4	15	ug/L
P-84	RM 18/16 BOYS RM	0.33	15	ug/L
P-85	CUST. SINK ACROSS FRM GYM	0.68	15	ug/L
P-86	BOYS RM ACROSS FRM GYM RT SINK	1.2	15	ug/L
P-87	BOYS RM ACROSS FRM GYM LFT SINK	0.64	15	ug/L
P-88	GIRLS ROOM ACROSS FRM GYM RT SINK	<0.10	15	ug/L
P-89	GIRLS ROOM ACROSS FRM GYM LFT SINK	<0.10	15	ug/L
P-90	WATER FOUNTAIN ACROSS FROM GYM	<0.10	15	ug/L
P-91	WATER FOUNTAIN TOP OF 5TH GRD WING	0.16	15	ug/L
P-92	WMNS RM SINK TOP OF 5TH GRD WING	0.56	15	ug/L
P-93	MENS RM SINK TOP OF 5TH GRD WING	1.1	15	ug/L
P-94	RM 34 SINK	<0.10	15	ug/L
P-95	RM 34 FOUNTAIN	0.39	15	ug/L
P-96	RM 34/36 GIRLS RM SINK	0.75	15	ug/L
P-97	RM 34/36 BOYS RM SINK	0.13	15	ug/L
P-98	RM 36 SINK	3.7	15	ug/L
P-99	RM 36 FOUNTAIN	0.76	15	ug/L
P-100	RM 38 SINK	O=61/R=2.3	15	ug/L
P-101	RM 38 FOUNTAIN	12.3	15	ug/L
P-102	RM 38/40 GIRLS RM SINK	1.7	15	ug/L
P-103	RM 38/40 BOYS RM SINK	0.51	15	ug/L
P-104	RM 40 SINK	4.8	15	ug/L
P-105	RM 40 FOUNTAIN	1.1	15	ug/L
P-106	RM 42 SINK	1.3	15	ug/L
P-107	RM 42 FOUNTAIN	0.69	15	ug/L
P-108	RM 42/44 GIRLS RM SINK	0.8	15	ug/L
P-109	RM 42/44 BOYS RM SINK	1.0	15	ug/L
P-109A	RM 44 SINK			
P-109B	RM 44 FOUNTAIN			
P-110	RM 43 SINK	1.2	15	ug/L
P-111	RM 43 FOUNTAIN	0.13	15	ug/L
P-112	RM 43/41 GIRLS RM	2.7	15	ug/L
P-113	RM 43/41 BOYS RM	1.2	15	ug/L
P-114	RM 41 SINK	3.2	15	ug/L
P-115	RM 41 FOUNTAIN	0.91	15	ug/L
P-116	RM 39 SINK	9.0	15	ug/L
P-117	RM 39 FOUNTAIN	1.8	15	ug/L
P-118	RM 39/37 GIRLS RM	1.7	15	ug/L

