



November 21, 2023

William Kotas  
Intertek PSI  
17 British American Boulevard  
Latham, NY 12110

RE: Project: PINWOOD ES 11/10  
Pace Project No.: 70277487

Dear William Kotas:

Enclosed are the analytical results for sample(s) received by the laboratory on November 13, 2023. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads "Lori Beyer".

Lori A. Beyer  
lori.beyer@pacelabs.com  
516-370-6014  
Project Manager

Enclosures



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

---

### **Pace Analytical Services Long Island**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-2		Lab ID: 70277487001	Collected: 11/10/23 07:58	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 19:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-4		Lab ID: 70277487002	Collected: 11/10/23 07:58	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 19:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-5		Lab ID: 70277487003	Collected: 11/10/23 08:00	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>14.9</b>	ug/L	1.0	1		11/17/23 19:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-6		Lab ID: 70277487004	Collected: 11/10/23 08:02	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.2</b>	ug/L	1.0	1		11/17/23 19:42	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-7		Lab ID: 70277487005	Collected: 11/10/23 08:02	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 19:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-8		Lab ID: 70277487006	Collected: 11/10/23 08:05	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		11/17/23 19:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-10		Lab ID: 70277487007	Collected: 11/10/23 08:05	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		11/17/23 19:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-11		Lab ID: 70277487008	Collected: 11/10/23 08:09	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 19:48	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-11A		Lab ID: 70277487009	Collected: 11/10/23 08:09	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 19:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-16		Lab ID: 70277487010	Collected: 11/10/23 08:15	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 19:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-16A		Lab ID: 70277487011	Collected: 11/10/23 08:15	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 19:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-17		Lab ID: 70277487012	Collected: 11/10/23 08:17	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-17A		Lab ID: 70277487013	Collected: 11/10/23 08:17	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>13.1</b>	ug/L	1.0	1		11/17/23 20:05	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-18		Lab ID: 70277487014	Collected: 11/10/23 08:17	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-19		Lab ID: 70277487015	Collected: 11/10/23 08:24	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-19A		Lab ID: 70277487016	Collected: 11/10/23 08:24	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-20		Lab ID: 70277487017	Collected: 11/10/23 08:24	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-21		Lab ID: 70277487018	Collected: 11/10/23 08:30	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-21A		Lab ID: 70277487019	Collected: 11/10/23 08:30	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-22		Lab ID: 70277487020	Collected: 11/10/23 08:30	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-23		Lab ID: 70277487021	Collected: 11/10/23 08:34	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		11/17/23 20:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-23A		Lab ID: 70277487022	Collected: 11/10/23 08:34	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.2</b>	ug/L	1.0	1		11/17/23 20:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-24		Lab ID: 70277487023	Collected: 11/10/23 08:34	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-25		Lab ID: 70277487024	Collected: 11/10/23 08:37	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-25A		Lab ID: 70277487025	Collected: 11/10/23 08:37	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		11/17/23 20:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-26		Lab ID: 70277487026	Collected: 11/10/23 08:37	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-27		Lab ID: 70277487027	Collected: 11/10/23 08:44	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.4</b>	ug/L	1.0	1		11/17/23 20:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-27A		Lab ID: 70277487028	Collected: 11/10/23 08:44	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.5</b>	ug/L	1.0	1		11/17/23 20:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-29		Lab ID: 70277487029	Collected: 11/10/23 08:46	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-29A		Lab ID: 70277487030	Collected: 11/10/23 08:46	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-31		Lab ID: 70277487031	Collected: 11/10/23 08:49	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.4</b>	ug/L	1.0	1		11/17/23 20:42	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-31A		Lab ID: 70277487032	Collected: 11/10/23 08:49	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		11/17/23 20:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-32		Lab ID: 70277487033		Collected: 11/10/23 08:49	Received: 11/13/23 15:15	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 20:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-33		Lab ID: 70277487034	Collected: 11/10/23 08:53	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.1	ug/L	1.0	1		11/17/23 20:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-34		Lab ID: 70277487035	Collected: 11/10/23 08:53	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>9.6</b>	ug/L	1.0	1		11/17/23 21:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-35		Lab ID: 70277487036	Collected: 11/10/23 08:55	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		11/17/23 21:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-36		Lab ID: 70277487037	Collected: 11/10/23 08:55	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.0</b>	ug/L	1.0	1		11/17/23 21:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-37		Lab ID: 70277487038	Collected: 11/10/23 08:59	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.4</b>	ug/L	1.0	1		11/17/23 21:05	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-38		Lab ID: 70277487039	Collected: 11/10/23 08:59	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-39		Lab ID: 70277487040	Collected: 11/10/23 09:01	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		11/17/23 21:11	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-40		Lab ID: 70277487041	Collected: 11/10/23 09:01	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.0</b>	ug/L	1.0	1		11/17/23 21:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-41		Lab ID: 70277487042	Collected: 11/10/23 09:02	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-42		Lab ID: 70277487043	Collected: 11/10/23 09:04	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-42A		Lab ID: 70277487044	Collected: 11/10/23 09:04	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-43		Lab ID: 70277487045	Collected: 11/10/23 09:11	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.2</b>	ug/L	1.0	1		11/17/23 21:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-44		Lab ID: 70277487046	Collected: 11/10/23 09:13	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		11/17/23 21:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-45		Lab ID: 70277487047	Collected: 11/10/23 09:15	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		11/17/23 21:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-46		Lab ID: 70277487048	Collected: 11/10/23 09:15	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-47		Lab ID: 70277487049	Collected: 11/10/23 09:17	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		11/17/23 21:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-48		Lab ID: 70277487050	Collected: 11/10/23 09:17	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-49		Lab ID: 70277487051	Collected: 11/10/23 09:28	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		11/17/23 21:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-50		Lab ID: 70277487052	Collected: 11/10/23 09:28	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-53		Lab ID: 70277487053	Collected: 11/10/23 09:37	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-54		Lab ID: 70277487054	Collected: 11/10/23 09:37	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:48	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-55		Lab ID: 70277487055	Collected: 11/10/23 09:43	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		11/17/23 21:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-56		Lab ID: 70277487056	Collected: 11/10/23 09:43	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		11/17/23 21:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-59		Lab ID: 70277487057	Collected: 11/10/23 10:10	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-60		Lab ID: 70277487058	Collected: 11/10/23 10:10	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-63		Lab ID: 70277487059	Collected: 11/10/23 10:15	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-64		Lab ID: 70277487060	Collected: 11/10/23 10:15	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 21:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-65		Lab ID: 70277487061	Collected: 11/10/23 10:17	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.7	ug/L	1.0	1		11/17/23 21:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-66		Lab ID: 70277487062	Collected: 11/10/23 10:17	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 22:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-69		Lab ID: 70277487063	Collected: 11/10/23 10:11	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 22:05	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-70		Lab ID: 70277487064	Collected: 11/10/23 10:11	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 22:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-71		Lab ID: 70277487065	Collected: 11/10/23 10:07	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 22:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-72		Lab ID: 70277487066	Collected: 11/10/23 10:07	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 22:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-75		Lab ID: 70277487067	Collected: 11/10/23 09:40	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 22:11	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-76		Lab ID: 70277487068	Collected: 11/10/23 09:40	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		11/17/23 22:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-92		Lab ID: 70277487069	Collected: 11/10/23 10:22	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 22:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-92A		Lab ID: 70277487070	Collected: 11/10/23 10:22	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 22:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-93		Lab ID: 70277487071	Collected: 11/10/23 10:26	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/17/23 22:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-93A		Lab ID: 70277487072	Collected: 11/10/23 10:26	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 20:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-96		Lab ID: 70277487073	Collected: 11/10/23 10:31	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 20:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-97		Lab ID: 70277487074	Collected: 11/10/23 10:31	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 20:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-100		Lab ID: 70277487075	Collected: 11/10/23 10:33	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-101		Lab ID: 70277487076	Collected: 11/10/23 10:33	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		11/20/23 21:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-102		Lab ID: 70277487077	Collected: 11/10/23 10:38	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-106		Lab ID: 70277487078	Collected: 11/10/23 10:45	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.3</b>	ug/L	1.0	1		11/20/23 21:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-107		Lab ID: 70277487079	Collected: 11/10/23 10:45	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		11/20/23 21:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-108		Lab ID: 70277487080	Collected: 11/10/23 10:50	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		11/20/23 21:21	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-109		Lab ID: 70277487081	Collected: 11/10/23 10:50	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		11/20/23 21:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-112		Lab ID: 70277487082	Collected: 11/10/23 10:51	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-113		Lab ID: 70277487083	Collected: 11/10/23 10:51	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-116		Lab ID: 70277487084	Collected: 11/10/23 10:47	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		11/20/23 21:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-117		Lab ID: 70277487085	Collected: 11/10/23 10:47	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: P-118</b>								
<b>Lab ID: 70277487086</b>								
Collected: 11/10/23 10:40								
Received: 11/13/23 15:15								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.7	ug/L	1.0	1		11/20/23 21:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-119		Lab ID: 70277487087	Collected: 11/10/23 10:40	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.9</b>	ug/L	1.0	1		11/20/23 21:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-122		Lab ID: 70277487088	Collected: 11/10/23 10:36	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-123		Lab ID: 70277487089	Collected: 11/10/23 10:36	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		11/20/23 21:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-124		Lab ID: 70277487090	Collected: 11/10/23 11:02	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.6	ug/L	1.0	1		11/20/23 21:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-128		Lab ID: 70277487091	Collected: 11/10/23 10:58	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:42	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-139		Lab ID: 70277487092	Collected: 11/10/23 09:25	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-140		Lab ID: 70277487093	Collected: 11/10/23 09:25	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.9</b>	ug/L	1.0	1		11/20/23 21:48	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-141		Lab ID: 70277487094	Collected: 11/10/23 09:34	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-142		Lab ID: 70277487095	Collected: 11/10/23 09:34	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.2</b>	ug/L	1.0	1		11/20/23 21:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-143		Lab ID: 70277487096	Collected: 11/10/23 09:47	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-144		Lab ID: 70277487097	Collected: 11/10/23 09:47	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 21:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-145		Lab ID: 70277487098	Collected: 11/10/23 09:54	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.9</b>	ug/L	1.0	1		11/20/23 15:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-146		Lab ID: 70277487099	Collected: 11/10/23 09:54	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 15:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-147		Lab ID: 70277487100	Collected: 11/10/23 10:54	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.2</b>	ug/L	1.0	1		11/20/23 15:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-148		Lab ID: 70277487101	Collected: 11/10/23 10:54	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 15:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P30		Lab ID: 70277487102	Collected: 11/10/23 08:46	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 15:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Sample: P-28		Lab ID: 70277487103	Collected: 11/10/23 08:44	Received: 11/13/23 15:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/23 15:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

QC Batch:	328087	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70277487001, 70277487002, 70277487003, 70277487004, 70277487005, 70277487006, 70277487007, 70277487008, 70277487009, 70277487010, 70277487011		

METHOD BLANK:	1678275	Matrix:	Water
Associated Lab Samples:	70277487001, 70277487002, 70277487003, 70277487004, 70277487005, 70277487006, 70277487007, 70277487008, 70277487009, 70277487010, 70277487011		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/17/23 19:09	

LABORATORY CONTROL SAMPLE:	1678276					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.0	100	85-115	

MATRIX SPIKE SAMPLE:	1678278						
Parameter	Units	70277487001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	49.0	97	70-130	

MATRIX SPIKE SAMPLE:	1678280						
Parameter	Units	70277487002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.5	96	70-130	

SAMPLE DUPLICATE:	1678277					
Parameter	Units	70277487001 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	1678279					
Parameter	Units	70277487002 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

QC Batch:	328088	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70277487012, 70277487013, 70277487014, 70277487015, 70277487016, 70277487017, 70277487018, 70277487019, 70277487020, 70277487021, 70277487022, 70277487023, 70277487024, 70277487025, 70277487026, 70277487027, 70277487028, 70277487029, 70277487030, 70277487031		

METHOD BLANK:	1678281	Matrix:	Water
Associated Lab Samples:	70277487012, 70277487013, 70277487014, 70277487015, 70277487016, 70277487017, 70277487018, 70277487019, 70277487020, 70277487021, 70277487022, 70277487023, 70277487024, 70277487025, 70277487026, 70277487027, 70277487028, 70277487029, 70277487030, 70277487031		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/17/23 19:57	

LABORATORY CONTROL SAMPLE:	1678282					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.2	100	85-115	

MATRIX SPIKE SAMPLE:	1678284						
Parameter	Units	70277487012 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.2	96	70-130	

MATRIX SPIKE SAMPLE:	1678286						
Parameter	Units	70277487013 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	13.1	50	59.8	94	70-130	

SAMPLE DUPLICATE:	1678283					
Parameter	Units	70277487012 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	1678285					
Parameter	Units	70277487013 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	13.1	12.9	1		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

QC Batch:	328089	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70277487032, 70277487033, 70277487034, 70277487035, 70277487036, 70277487037, 70277487038, 70277487039, 70277487040, 70277487041, 70277487042, 70277487043, 70277487044, 70277487045, 70277487046, 70277487047, 70277487048, 70277487049, 70277487050, 70277487051		

METHOD BLANK:	1678287	Matrix:	Water
Associated Lab Samples:	70277487032, 70277487033, 70277487034, 70277487035, 70277487036, 70277487037, 70277487038, 70277487039, 70277487040, 70277487041, 70277487042, 70277487043, 70277487044, 70277487045, 70277487046, 70277487047, 70277487048, 70277487049, 70277487050, 70277487051		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/17/23 20:43	

LABORATORY CONTROL SAMPLE:	1678288					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.0	100	85-115	

MATRIX SPIKE SAMPLE:	1678290						
Parameter	Units	70277487032 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.0	50	49.0	96	70-130	

MATRIX SPIKE SAMPLE:	1678292						
Parameter	Units	70277487033 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	47.6	95	70-130	

SAMPLE DUPLICATE:	1678289					
Parameter	Units	70277487032 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	1.0	1.0	1		

SAMPLE DUPLICATE:	1678291					
Parameter	Units	70277487033 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

QC Batch:	328091	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70277487052, 70277487053, 70277487054, 70277487055, 70277487056, 70277487057, 70277487058, 70277487059, 70277487060, 70277487061, 70277487062, 70277487063, 70277487064, 70277487065, 70277487066, 70277487067, 70277487068, 70277487069, 70277487070, 70277487071		

METHOD BLANK:	1678303	Matrix:	Water
Associated Lab Samples:	70277487052, 70277487053, 70277487054, 70277487055, 70277487056, 70277487057, 70277487058, 70277487059, 70277487060, 70277487061, 70277487062, 70277487063, 70277487064, 70277487065, 70277487066, 70277487067, 70277487068, 70277487069, 70277487070, 70277487071		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/17/23 21:33	

LABORATORY CONTROL SAMPLE:	1678304					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.8	100	85-115	

MATRIX SPIKE SAMPLE:	1678306						
Parameter	Units	70277487052 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.2	95	70-130	

MATRIX SPIKE SAMPLE:	1678308						
Parameter	Units	70277487053 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	47.9	95	70-130	

SAMPLE DUPLICATE:	1678305					
Parameter	Units	70277487052 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	1678307					
Parameter	Units	70277487053 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

QC Batch:	328267	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70277487072, 70277487073, 70277487074, 70277487075, 70277487076, 70277487077		

METHOD BLANK:	1679500	Matrix:	Water
Associated Lab Samples:	70277487072, 70277487073, 70277487074, 70277487075, 70277487076, 70277487077		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/20/23 20:17	

LABORATORY CONTROL SAMPLE: 1679501						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.7	105	85-115	

MATRIX SPIKE SAMPLE: 1679503							
Parameter	Units	70277511090 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.8	97	70-130	

MATRIX SPIKE SAMPLE: 1679505							
Parameter	Units	70277511091 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.6	97	70-130	

SAMPLE DUPLICATE: 1679502					
Parameter	Units	70277511090 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1679504					
Parameter	Units	70277511091 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

QC Batch:	328268	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70277487078, 70277487079, 70277487080, 70277487081, 70277487082, 70277487083, 70277487084, 70277487085, 70277487086, 70277487087, 70277487088, 70277487089, 70277487090, 70277487091, 70277487092, 70277487093, 70277487094, 70277487095, 70277487096, 70277487097		

METHOD BLANK:	1679508	Matrix:	Water
Associated Lab Samples:	70277487078, 70277487079, 70277487080, 70277487081, 70277487082, 70277487083, 70277487084, 70277487085, 70277487086, 70277487087, 70277487088, 70277487089, 70277487090, 70277487091, 70277487092, 70277487093, 70277487094, 70277487095, 70277487096, 70277487097		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/20/23 21:08	

LABORATORY CONTROL SAMPLE:	1679509					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.3	105	85-115	

MATRIX SPIKE SAMPLE:	1679511						
Parameter	Units	70277487078 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.3	50	52.5	96	70-130	

MATRIX SPIKE SAMPLE:	1679513						
Parameter	Units	70277487079 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.4	50	49.2	96	70-130	

SAMPLE DUPLICATE:	1679510					
Parameter	Units	70277487078 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	4.3	4.4	1		

SAMPLE DUPLICATE:	1679512					
Parameter	Units	70277487079 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	1.4	1.4	0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

QC Batch:	328269	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70277487098, 70277487099, 70277487100, 70277487101, 70277487102, 70277487103

METHOD BLANK: 1679514 Matrix: Water  
 Associated Lab Samples: 70277487098, 70277487099, 70277487100, 70277487101, 70277487102, 70277487103

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/20/23 15:26	

LABORATORY CONTROL SAMPLE: 1679515

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.5	105	85-115	

MATRIX SPIKE SAMPLE: 1679517

Parameter	Units	70277487098 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.9	50	51.6	99	70-130	

MATRIX SPIKE SAMPLE: 1679519

Parameter	Units	70277487099 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.4	96	70-130	

SAMPLE DUPLICATE: 1679516

Parameter	Units	70277487098 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.9	1.8	2	

SAMPLE DUPLICATE: 1679518

Parameter	Units	70277487099 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.





## QUALIFIERS

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

### WORKORDER QUALIFIERS

WO: 70277487

[1] SAMPLE DISCREPANCY DOCUMENTED ON SAMPLE RECEIPT FORM. CLIENT SUBMITTED REVISED CHAIN.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70277487001	P-2	EPA 200.8	328087		
70277487002	P-4	EPA 200.8	328087		
70277487003	P-5	EPA 200.8	328087		
70277487004	P-6	EPA 200.8	328087		
70277487005	P-7	EPA 200.8	328087		
70277487006	P-8	EPA 200.8	328087		
70277487007	P-10	EPA 200.8	328087		
70277487008	P-11	EPA 200.8	328087		
70277487009	P-11A	EPA 200.8	328087		
70277487010	P-16	EPA 200.8	328087		
70277487011	P-16A	EPA 200.8	328087		
70277487012	P-17	EPA 200.8	328088		
70277487013	P-17A	EPA 200.8	328088		
70277487014	P-18	EPA 200.8	328088		
70277487015	P-19	EPA 200.8	328088		
70277487016	P-19A	EPA 200.8	328088		
70277487017	P-20	EPA 200.8	328088		
70277487018	P-21	EPA 200.8	328088		
70277487019	P-21A	EPA 200.8	328088		
70277487020	P-22	EPA 200.8	328088		
70277487021	P-23	EPA 200.8	328088		
70277487022	P-23A	EPA 200.8	328088		
70277487023	P-24	EPA 200.8	328088		
70277487024	P-25	EPA 200.8	328088		
70277487025	P-25A	EPA 200.8	328088		
70277487026	P-26	EPA 200.8	328088		
70277487027	P-27	EPA 200.8	328088		
70277487028	P-27A	EPA 200.8	328088		
70277487029	P-29	EPA 200.8	328088		
70277487030	P-29A	EPA 200.8	328088		
70277487031	P-31	EPA 200.8	328088		
70277487032	P-31A	EPA 200.8	328089		
70277487033	P-32	EPA 200.8	328089		
70277487034	P-33	EPA 200.8	328089		
70277487035	P-34	EPA 200.8	328089		
70277487036	P-35	EPA 200.8	328089		
70277487037	P-36	EPA 200.8	328089		
70277487038	P-37	EPA 200.8	328089		
70277487039	P-38	EPA 200.8	328089		
70277487040	P-39	EPA 200.8	328089		
70277487041	P-40	EPA 200.8	328089		
70277487042	P-41	EPA 200.8	328089		
70277487043	P-42	EPA 200.8	328089		
70277487044	P-42A	EPA 200.8	328089		
70277487045	P-43	EPA 200.8	328089		
70277487046	P-44	EPA 200.8	328089		
70277487047	P-45	EPA 200.8	328089		
70277487048	P-46	EPA 200.8	328089		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70277487049	P-47	EPA 200.8	328089		
70277487050	P-48	EPA 200.8	328089		
70277487051	P-49	EPA 200.8	328089		
70277487052	P-50	EPA 200.8	328091		
70277487053	P-53	EPA 200.8	328091		
70277487054	P-54	EPA 200.8	328091		
70277487055	P-55	EPA 200.8	328091		
70277487056	P-56	EPA 200.8	328091		
70277487057	P-59	EPA 200.8	328091		
70277487058	P-60	EPA 200.8	328091		
70277487059	P-63	EPA 200.8	328091		
70277487060	P-64	EPA 200.8	328091		
70277487061	P-65	EPA 200.8	328091		
70277487062	P-66	EPA 200.8	328091		
70277487063	P-69	EPA 200.8	328091		
70277487064	P-70	EPA 200.8	328091		
70277487065	P-71	EPA 200.8	328091		
70277487066	P-72	EPA 200.8	328091		
70277487067	P-75	EPA 200.8	328091		
70277487068	P-76	EPA 200.8	328091		
70277487069	P-92	EPA 200.8	328091		
70277487070	P-92A	EPA 200.8	328091		
70277487071	P-93	EPA 200.8	328091		
70277487072	P-93A	EPA 200.8	328267		
70277487073	P-96	EPA 200.8	328267		
70277487074	P-97	EPA 200.8	328267		
70277487075	P-100	EPA 200.8	328267		
70277487076	P-101	EPA 200.8	328267		
70277487077	P-102	EPA 200.8	328267		
70277487078	P-106	EPA 200.8	328268		
70277487079	P-107	EPA 200.8	328268		
70277487080	P-108	EPA 200.8	328268		
70277487081	P-109	EPA 200.8	328268		
70277487082	P-112	EPA 200.8	328268		
70277487083	P-113	EPA 200.8	328268		
70277487084	P-116	EPA 200.8	328268		
70277487085	P-117	EPA 200.8	328268		
70277487086	P-118	EPA 200.8	328268		
70277487087	P-119	EPA 200.8	328268		
70277487088	P-122	EPA 200.8	328268		
70277487089	P-123	EPA 200.8	328268		
70277487090	P-124	EPA 200.8	328268		
70277487091	P-128	EPA 200.8	328268		
70277487092	P-139	EPA 200.8	328268		
70277487093	P-140	EPA 200.8	328268		
70277487094	P-141	EPA 200.8	328268		
70277487095	P-142	EPA 200.8	328268		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: PINEWOOD ES 11/10

Pace Project No.: 70277487

---

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70277487096	P-143	EPA 200.8	328268		
70277487097	P-144	EPA 200.8	328268		
70277487098	P-145	EPA 200.8	328269		
70277487099	P-146	EPA 200.8	328269		
70277487100	P-147	EPA 200.8	328269		
70277487101	P-148	EPA 200.8	328269		
70277487102	P30	EPA 200.8	328269		
70277487103	P-28	EPA 200.8	328269		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

LAB USE ONLY - AMX WorkOrder Login Label Here  
**WO#: 70277487**

Company Name: INTERTEKLEAD  
 Street Address: 17 British American Blvd, Latham, NY 12110  
 Customer Project #: 08215316  
 Project Name: Mohonassen CSD/CB-Bores  
 Site Collection Info/Facility ID (as applicable): **PANEWOOD E.S.**

Contact/Report To: Kotas, William  
 Phone #: 518-377-9841  
 E-Mail: william.kotas@intertek.com  
 Cc E-Mail:

Time Zone Collected: [ ] AK [ ] MT [ ] CT [ ] ET  
 Regulatory Program (DW, RCRA, etc.) as applicable: New York  
 Rush (Pre-approval required):  
 [ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other  
 Date Results Requested: **STD.**  
 Field Filtered (if applicable): [ ] Yes [ ] No  
 Analyte:

Specify Container Size \*\*  
 Identify Container Preservative Type \*\*\*  
 Analysis Requested

Customer Sample ID	Matrix * (or Composite Start)	Collected		Composite End		Res. CL	Number & Type of Containers	200 g Lead
		Date	Time	Date	Time			
P-2	DW G	11/10/23	7:58				1	X
P-4			7:58					
P-5			8:00					
P-6			8:02					
P-7			8:02					
P-8			8:05					
P-10			8:05					
P-11			8:09					
P-11A			8:09					
P-16			8:15					

Proj. Mgr: **Lori Bayer**  
 AcctNum / Client ID:  
 Table #:  
 Profile / Template:  
 X  
 Preg / Bottle Ord. ID: **1152943**  
 Sample Comment

Customer Remarks / Special Conditions / Possible Hazards:  
**POTABLE LEAD**

Collected By: **WILLIAM A. KOTAS**  
 Printed Name: *William A. Kotas*  
 Signature: *William A. Kotas*

Received by/Company: (Signature) *PAE*  
 Date/Time: 11/13/23 15:15

Received by/Company: (Signature) *PAE*  
 Date/Time: 11/13 16:00

Received by/Company: (Signature) *PAE*  
 Date/Time: 11/13/23 7:40

Additional Instructions from Pace\*:  
 Thermocouple ID: **T1418**  
 Correction Factor (°C): **+0.3**  
 Obs. Temp. (°C): **16.2**  
 Corrected Temp. (°C): **16.5**  
 # Coolers: **1**  
 Trading Number:

Date/Time: 11/13/23 15:15  
 Date/Time: 11/13/23 16:00  
 Date/Time: 11/13/23 7:40

Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other

Page: 1 of 1



Scan QR Code for instructions

**CHAIN-OF-CUSTODY Analytical Request Document**

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**Pace\***  
 Pace\* Location Requested (City/State):  
 Pace Analytical Long Island NY  
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: INTERTEKLEAD  
 Street Address: 17 British American Blvd, Latham, NY 12110

Contact/Report To: Kotas, William  
 Phone #: 518-377-9841  
 E-Mail: william.kotas@intertek.com  
 Cc E-Mail:

Customer Project #: 08215316  
 Project Name: Mohanasen CSD/CR-Boxes  
 PINEWOOD E.S.  
 Site Collection Info/Facility ID (as applicable):

Invoice To:  
 Invoice E-Mail:  
 Purchase Order # (if applicable):  
 Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable:  
 Rush (pre-approval required):  
 [ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other:  
 Date Results Requested: STD.  
 Field Filtered (if applicable): [ ] Yes [ ] No  
 Analytic:

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Composite End	Res. CLZ	Number & Type of Containers		Sample Comment
			Date	Time			Plastic	Glass	
P-16A	DW	G	11/10/23	8:15			1		
P-17				8:17					
P-17A				8:17					
P-18				8:17					
P-19				8:24					
P-19A									
P-20									
P-21				8:30					
P-21A									
P-22									

Additional Instructions from Pace\*:  
 Collected By: WILLIAM A. KOTAS  
 Printed Name: [Signature]  
 Signature: [Signature]

Received by/Company: [Signature] PACE  
 Date/Time: 11/13/23 15:15

Received by/Company: [Signature] PACE  
 Date/Time: 11/13/23 16:00

Received by/Company: [Signature] PACE  
 Date/Time: 11/13/23 22:00

Received by/Company: [Signature] PACE  
 Date/Time: 11/13/23 22:00

Tracking Number:  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other  
 Page: 2 of 1

Rate Location Requested (City/State):  
 Pace Analytical Long Island NY  
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: INTERTEKLEAD  
 Street Address: 17 British American Blvd, Latham, NY 12110

Customer Project #: 08215316  
 Project Name: Mohonasen CSD/CR-Boxes  
 PANEWOOD E.S.  
 Site Collection Info/Facility ID (as applicable):

Contact/Report To: Kotas, William  
 Phone #: 518-377-9841  
 E-Mail: william.kotas@intertek.com  
 Cc E-Mail:

Invoice To:  
 Invoice E-Mail:  
 Purchase Order # (if applicable):  
 Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable:  
 Rush (Pre-approval required):  
 [ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other  
 Date Results Requested: STD.

Time Zone Collected: [ ] AK [ ] MT [ ] PT [ ] CT [ ] ET

Matrix *	Comp / Grab	Collected (or Composite Start) Date	Time	Composite End Date	Time	Res. CL	Number & Type of Containers
		Date		Date			Plastic Glass
P-23	G	11/10/23	8:34				1
P-23A			↓				
P-24			8:37				
P-25			↓				
P-25A			8:41				
P-26			↓				
P-27			↓				
P-27A			8:46				
P-29			↓				
P-29A			↓				

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Field Filtered (if applicable): [ ] Yes [ ] No  
 Analytic: 200 g Lead

Additional Instructions from Pace:  
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number:  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other  
 Page: 3 of 11

Received by/Company: Signature: WILLIAM A. KOTAS  
 Received by/Company: Signature: [Signature]  
 Received by/Company: Signature: [Signature]  
 Received by/Company: Signature: [Signature]

Date/Time: 11/13/23 15:15  
 Date/Time: 11/13/23 16:00  
 Date/Time: 11/19/23  
 Date/Time:



Scan QR Code for instructions

### CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**Pace**  
 Pace Analytical Long Island NY  
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: INTERTEKLEAD  
 Street Address: 17British American Blvd, Latham, NY 12110

Contact/Report To: Kotas, William  
 Phone #: 518-377-9841  
 E-Mail: william.kotas@intertek.com  
 Cc E-Mail:

Customer Project #: 08215316  
 Project Name: Mahonassen CSD/CR-Boces  
 PINEWOOD E.S.  
 Site Collection Info/Facility ID (as applicable):

Invoice To:  
 Invoice E-Mail:  
 Purchase Order # (if applicable):  
 Quote #:

Time Zone Collected: [ ] AK [ ] MT [ ] CT [ ] ET  
 Regulatory Program (DW, RCRA, etc.) as applicable: New York  
 Rush (Pre-approval required):  
 [ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other  
 Date Results Requested: **STD.**  
 Field Filtered (if applicable): [ ] Yes [ ] No  
 Analysis:

DW PWSID # or WW Permit # as applicable:  
 Matrix \*  
 [ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other  
 Date Results Requested: **STD.**  
 Field Filtered (if applicable): [ ] Yes [ ] No  
 Analysis:

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OO), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Res. CLZ	Composite End		Number & Type of Containers	Preservation non-conformance identified for sample
			Date	Time		Date	Time		
P-31	DW	G	11/10/23	8:49				1	
P-31A									
P-32									
P-33									
P-34									
P-35									
P-36									
P-37									
P-38									
P-39									

Additional Instructions from Pace\*:  
 Collected By: **WILLIAM A. KOTAS**  
 Printed Name: *[Signature]*  
 Signature: *[Signature]*  
 Received by/Company: (Signature) *[Signature]* **PACE**  
 Received by/Company: (Signature) *[Signature]*  
 Received by/Company: (Signature) *[Signature]*  
 Received by/Company: (Signature) *[Signature]*

# Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number: 11/13/23 1515  
 Date/Time: 11/13/23 1600  
 Date/Time: 11/14/23 7:16  
 Date/Time: 11/14/23 7:16

Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other

Page: 4 of 11







Scan QR Code for instructions

LAB USE ONLY - Amix Workorder/Login Label Here

### CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**Pace**  
 Pace Analytical Long Island NY  
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: INTERTEKLEAD  
 Street Address: 17 British American Blvd, Latham, NY 12110

Contact/Report To: Kotas, William  
 Phone #: 518-377-9841  
 E-Mail: william.kotas@intertek.com  
 Ct. E-Mail:

Customer Project #: 08215316  
 Project Name: Mohonasen CSD/CR-Boxes  
 RINEWOOD ES.

Invoice To:  
 Invoice E-Mail:  
 Purchase Order # (if applicable):  
 Quote #: x

Time Zone Collected: [ ] AK [ ] MT [ ] CT [ ] ET  
 County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable:

Rush (Pre-approval required):  
 [ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other  
 Date Requested: STD.

DW PWSID # or WW Permit # as applicable:  
 Field Filtered (if applicable): [ ] Yes [ ] No  
 Analysis:

\* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OI), Wipe (WI), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Res. CL2	Composite End		Number & Type of Containers	Sample Comment
			Date	Time		Date	Time		
P-49	DW G		11/10/23	9:28				1	
P-50				9:37					
P-53				9:43					
P-54									
P-55									
P-56				10:10					
P-59									
P-60									
P-63				10:15					
P-64									

Additional instructions from Pace:

Collected By: WILLIAM A. KOTAS  
 Printed Name: [Signature]  
 Signature: [Signature]

Received by/Company: [Signature] PACE  
 Date/Time: 11/13/23 15:15

Received by/Company: [Signature]  
 Date/Time: 11/13/23 16:00

Received by/Company: [Signature] PACE  
 Date/Time: 11/13/23 10:00

Received by/Company: [Signature] PACE  
 Date/Time: 11/13/23 11:43

Tracking Number:  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other  
 Page: 6 of 11



LAB USE ONLY - Amx WordorderLogin Label Here

Specify Container Size \*\*  
Identify Container Preservative Type\*\*

Analysis Requested

Proj. Mgr:  
AcctNum / Client ID:  
Table #:  
Profile / Template:  
Prelog / Bottle Ord. ID:  
1152043

Sample Comment

Additional Instructions from Pace\*

# Coolers: Thermometer ID: Obs. Temp. (°C) Correction Factor (°C) Corrected Temp. (°C)  
Date/Time: 11/13/23 15:15  
Date/Time:  
Date/Time: 11/13/23 20:09  
Date/Time:

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Customer Project #  
Project Name:  
Site Collection info/Facility ID (as applicable):

Country / State origin of sample(s):  
Regulatory Program (DW, RCMA, etc) as applicable:  
Rush (Pre-approval required):  
Date Results Requested: STD.

Matrix \*  
Comp / Grab  
Date  
Time  
Composite End  
Date  
Time  
Res. CL2  
Number & Type of Containers  
Plastic Glass

Table with columns for Matrix, Comp/Grab, Date, Time, Composite End, Date, Time, Res. CL2, and Number & Type of Containers. Rows include samples P-65, P-66, P-69, P-70, P-71, P-72, P-75, P-76, P-92, and P-92A.

Collected By: WILLIAM A. KOTAS  
Printed Name  
Signature:  
Received by/Company: (Signature)  
Received by/Company: (Signature)  
Received by/Company: (Signature)  
Received by/Company: (Signature)

Pace\* Location Requested (City/State):  
Pace Analytical Long Island NY  
575 Broad Hollow Rd, Melville, NY 11747

Company Name: INTERTEKLEAD  
Street Address: 17 British American Blvd., Latham, NY 12110

Time Zone Collected: [ ] AK [ ] MT [ ] CT [ ] ET  
Date Deliverables:  
Level II [ ] Level III [ ] Level IV  
Level I [ ] EQUIS [ ] Other

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Remarks / Special Conditions / Possible Hazards:  
POTABLE LEAD

Relinquished by/Company: (Signature)  
Relinquished by/Company: (Signature)  
Relinquished by/Company: (Signature)  
Relinquished by/Company: (Signature)

Company Name: INTERTEKLEAD  
Street Address: 17 British American Blvd., Latham, NY 12110  
Customer Project #: 08215316  
Project Name: Mohonasen CSD/CR-Boces  
Site Collection info/Facility ID (as applicable): ANEWOOD E.S.

Contact/Report To: Kotas, William  
Phone #: 518-377-9841  
E-Mail: william.kotas@intertek.com  
Cc E-Mail:  
Invoice To:  
Invoice E-Mail:  
Purchase Order # (if applicable):  
Quote #: X

Country / State origin of sample(s): New York  
Regulatory Program (DW, RCMA, etc) as applicable:  
Rush (Pre-approval required):  
Date Results Requested: STD.

Matrix \*  
Comp / Grab  
Date  
Time  
Composite End  
Date  
Time  
Res. CL2  
Number & Type of Containers  
Plastic Glass

Table with columns for Matrix, Comp/Grab, Date, Time, Composite End, Date, Time, Res. CL2, and Number & Type of Containers. Rows include samples P-65, P-66, P-69, P-70, P-71, P-72, P-75, P-76, P-92, and P-92A.

Collected By: WILLIAM A. KOTAS  
Printed Name  
Signature:  
Received by/Company: (Signature)  
Received by/Company: (Signature)  
Received by/Company: (Signature)  
Received by/Company: (Signature)



LAB USE ONLY - Amix Workorder/Login Label Here

Scan QR Code for Instructions

### CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Face® Location Requested (City/State):  
 Pace Analytical Long Island NY  
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: INTERTEK LEAD  
 Street Address: 17 British American Blvd, Latham, NY 12110

Customer Project #: 08215316  
 Project Name: Mohonasen CSD/CR-Boxes  
 RINEWOOD E.S.

Site Collection Info/Facility ID (as applicable):

Contact/Report To: Kotas, William  
 Phone #: 518-377-9841  
 E-Mail: william.kotas@intertek.com  
 Cc E-Mail:

Invoice To:

Invoice E-Mail:

Purchase Order # (if applicable):

Quote #: x

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable:

Rush (Pre-approval required):

Date Requested: STD.

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): [ ] Yes [ ] No

Analysis:

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End	Res. CLZ	Number & Type of Containers		200 or Lead
			Date	Time			Date	Time	
P-93	DW	G	11/10/23	10:26			1		X
P-93A				↓					
P-96				10:31					
P-97				↓					
P-100				10:33					
P-101				↓					
P-102				10:38					
P-106				10:45					
P-107				↓					
P-108				10:50					

Customer Remarks / Special Conditions / Possible Hazards:  
 POTABLE LEAD

Collected By: WILLIAM A. KOTAS  
 Printed Name: [Signature]  
 Signature: [Signature]

Relinquished by/Company (Signature)	Date/Time	Received by/Company (Signature)	Date/Time
[Signature]	11/13/23 1513	[Signature]	11/13/23 1515
[Signature]	11/13/23 1600	[Signature]	11/13/23 1600
[Signature]	11/13/23 7464	[Signature]	11/13/23 1600

Additional Instructions from Pace\*:  
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number:  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other  
 Page: 8 of 11

ENV-FRM-CORQ-0019\_v01\_082123 ©

Company Name: INTERTEKLEAD  
 Street Address: 177 British American Blvd, Latham, NY 12110

Customer Project #: 08215316  
 Project Name: Mohonassen CSD/CR-Boces  
 RINEWOOD E.S.

Site Collection Info/Facility ID (as applicable):  
 Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET

Contact/Report To: Kotas, William  
 Phone #: 518-377-9841  
 E-Mail: william.kotas@intertek.com  
 Cc E-Mail:

Invoice To:  
 Invoice E-Mail:  
 Purchase Order # (if applicable):  
 Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable:  
 Rush (Pre-approval required):  
 Date Results Requested: STD.

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (PI), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Specify Container Size \*\*  
 Identify Container Preservative Type \*\*\*  
 Analysis Requested

\*\* Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vol, (7) Encore, (8) TerraCore, (9) Other  
 \*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Proj. Mfr: **Loft Beyer**  
 Account / Client ID:  
 Table #:  
 Profile / Template:  
 Prelog / Bottle Ord. ID: **1152843**

Sample Comment

Additional Instructions from Pace\*  
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number:  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other

Date/Time: 11/13/23 1515  
 Date/Time: 11/19/23 20:00

Date/Time: 11/13/23 1313  
 Date/Time: 11/13 1600  
 Date/Time: 11/14/23  
 Date/Time: 11/13 7400

Received by/Company: Signature: **WILLIAM A. KOTAS**  
 Received by/Company: Signature: **PAE**  
 Received by/Company: Signature: **PAE**  
 Received by/Company: Signature: **PAE**

Customer Remarks / Special Conditions / Possible Hazards:  
 POTABLE LEAD

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - AMTix Workorder/Login Label Here  
 Scan QR Code for instructions

200 g Lead

Number & Type of Containers  
 Plastic Glass

Res. CLZ  
 Composite End Date Time

Collected (or Composite Start) Date Time  
 Matrix \* Comp / Grab

Field Filtered (if applicable): [ ] Yes [ ] No  
 Analysis: STD.

Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other [ ]  
 DW G 11/10/23 10:50  
 P-109  
 P-112  
 P-113  
 P-116  
 P-117  
 P-118  
 P-119  
 P-122  
 P-123  
 P-124

Additional Instructions from Pace\*  
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number:  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other

Date/Time: 11/13/23 1515  
 Date/Time: 11/19/23 20:00

Date/Time: 11/13/23 1313  
 Date/Time: 11/13 1600  
 Date/Time: 11/14/23  
 Date/Time: 11/13 7400

Received by/Company: Signature: **WILLIAM A. KOTAS**  
 Received by/Company: Signature: **PAE**  
 Received by/Company: Signature: **PAE**  
 Received by/Company: Signature: **PAE**

Customer Remarks / Special Conditions / Possible Hazards:  
 POTABLE LEAD

Customer Project #: 08215316  
 Project Name: Mohonassen CSD/CR-Boces  
 RINEWOOD E.S.

Site Collection Info/Facility ID (as applicable):  
 Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET

Contact/Report To: Kotas, William  
 Phone #: 518-377-9841  
 E-Mail: william.kotas@intertek.com  
 Cc E-Mail:

Invoice To:  
 Invoice E-Mail:  
 Purchase Order # (if applicable):  
 Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable:  
 Rush (Pre-approval required):  
 Date Results Requested: STD.

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (PI), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Specify Container Size \*\*  
 Identify Container Preservative Type \*\*\*  
 Analysis Requested

Proj. Mfr: **Loft Beyer**  
 Account / Client ID:  
 Table #:  
 Profile / Template:  
 Prelog / Bottle Ord. ID: **1152843**

Sample Comment

Additional Instructions from Pace\*  
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number:  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other

Date/Time: 11/13/23 1515  
 Date/Time: 11/19/23 20:00

Date/Time: 11/13/23 1313  
 Date/Time: 11/13 1600  
 Date/Time: 11/14/23  
 Date/Time: 11/13 7400

Received by/Company: Signature: **WILLIAM A. KOTAS**  
 Received by/Company: Signature: **PAE**  
 Received by/Company: Signature: **PAE**  
 Received by/Company: Signature: **PAE**

Customer Remarks / Special Conditions / Possible Hazards:  
 POTABLE LEAD

Customer Project #: 08215316  
 Project Name: Mohonassen CSD/CR-Boces  
 RINEWOOD E.S.

Site Collection Info/Facility ID (as applicable):  
 Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET

Contact/Report To: Kotas, William  
 Phone #: 518-377-9841  
 E-Mail: william.kotas@intertek.com  
 Cc E-Mail:

Invoice To:  
 Invoice E-Mail:  
 Purchase Order # (if applicable):  
 Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable:  
 Rush (Pre-approval required):  
 Date Results Requested: STD.

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (PI), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Specify Container Size \*\*  
 Identify Container Preservative Type \*\*\*  
 Analysis Requested

Proj. Mfr: **Loft Beyer**  
 Account / Client ID:  
 Table #:  
 Profile / Template:  
 Prelog / Bottle Ord. ID: **1152843**

Sample Comment

Additional Instructions from Pace\*  
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number:  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other

Date/Time: 11/13/23 1515  
 Date/Time: 11/19/23 20:00

Date/Time: 11/13/23 1313  
 Date/Time: 11/13 1600  
 Date/Time: 11/14/23  
 Date/Time: 11/13 7400

Received by/Company: Signature: **WILLIAM A. KOTAS**  
 Received by/Company: Signature: **PAE**  
 Received by/Company: Signature: **PAE**  
 Received by/Company: Signature: **PAE**

Customer Remarks / Special Conditions / Possible Hazards:  
 POTABLE LEAD

Customer Project #: 08215316  
 Project Name: Mohonassen CSD/CR-Boces  
 RINEWOOD E.S.

Site Collection Info/Facility ID (as applicable):  
 Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET



Scan QR Code for instructions

### CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Pace® Location Requested (City/State):  
Pace Analytical Long Island NY  
575 Broad Hollow Rd, Melville, NY 11747

Company Name: INTERTEK LEAD  
Street Address: 17 British American Blvd, Latham, NY 12110

Contact/Report To: Kotas, William  
Phone #: 518-377-9841  
E-Mail: william.kotas@intertek.com  
Cc E-Mail:

Customer Project #: 08215316  
Project Name: Mohonasen CSD/CR-Boxes  
PINEWOOD E.S.  
Site Collection Info/Facility ID (as applicable):

Invoice To:  
Invoice E-Mail:  
Purchase Order # (if applicable):  
Quote #: x

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable:

Rush (Pre-approval required):  
[ ] 12 Day [ ] 3 day [ ] 15 day [ ] Other  
Date Results Requested: STD.

DW PWSID # or WW Permit # as applicable:  
Field Filtered (if applicable): [ ] Yes [ ] No  
Analysis:

\* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OI), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Cask

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End		Res. CL2	Number & Type of Containers		Sample Comment
			Date	Time	Date	Time		Plastic	Glass	
P-128	DW	G	11/10/23	10:58				1		
P-139				9:25						
P-140				9:34						
P-141				9:47						
P-142				9:54						
P-143										
P-144										
P-145										
P-146										
P-147				10:54						

Customer Remarks / Special Conditions / Possible Hazards:  
POTABLE LEAD

Additional instructions from Pace\*:  
# Coolers: Thermometer ID: Obs. Temp. (°C) Correction Factor (°C):

Relinquished by/Company: Signature		Date/Time	Received by/Company: Signature		Date/Time
<i>[Signature]</i>		11/13/23 15:15	<i>[Signature]</i>		11/13/23 15:15
<i>[Signature]</i>		11/13/23 16:00	<i>[Signature]</i>		11/13/23 16:00
<i>[Signature]</i>		11/13/23 7:10A	<i>[Signature]</i>		11/13/23 7:10A







**WO#: 70277487**

Client Name: INTERTEK LEAD Project

**PM: LAB Due Date: 11/30/23**  
**CLIENT: INTERTEK LEAD**

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pac  Other

Tracking #: \_\_\_\_\_

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No Temperature Blank Present:  Yes  No  
 Packing Material:  Bubble Wrap  Bubble Bags  Ziplo  Non  Other Type of Ice: Wet Blue None

Thermometer Used: TH1148 Correction Factor: +0.3  Samples on ice, cooling process has begun  
 Cooler Temperature (°C): 16.2 Cooler Temperature Corrected (°C): 16.5 Date/Time 5035A kits placed in freezer \_\_\_\_\_

Temp should be above freezing to 6.0°C

USDA Regulated Soil ( N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: WR 11/14/23

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container,
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: <u>SL WT OIL OTHER</u>	

Date and Initials of person checking preservation: WR 11/14/23

All containers needing preservation have been <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A pH paper Lot # <u>HC208072</u>	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH > 9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH > 12 Cyanide)	Sample #
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A KI starch test strips Lot #	14. Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #	15. Positive for Sulfide? Y N
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Lead Acetate Strips Lot #	17.
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

DATE AND INITIALS OF PERSON COMPLETING SECOND REVIEW: WR 11/14/23

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted: William Kotas

Date/Time: 11/14/23 16:25

Comments/ Resolution:

Container P-41 with collection time 9:07 was labeled with P42. Received two P-41's.  
P-48 received two bottles | P-28 not on COC  
P-47 received two bottles | P-69 not on COC  
Received two bottles

\* PM (Project Manager) review is documented electronically in LIMS.

emailed William Kotas regarding, missing sample ID on COC, discrepancy in collection time